

# Short shunt compound dc generator

## Short shunt compound dc generator

The compound wound motor is further categorised into short-shunt and long ...

A DC generator requires MMF to establish flux in its magnetic circuit. The MMF necessary to establish flux in the magnetic circuit of a dc generator is obtained by field excitation.

When a DC voltage is applied to the field windings of a DC generator, current flows through the windings and sets up a steady magnetic field. This is called field excitation. Please go through the construction of dc generator before reading this article about different types of dc generator.

Field excitation can be obtained by the following means: Permanent magnets, Field coils excited from some external source, and Field coils excited by the generator itself. The excitation voltage can be produced by the generator itself or it can be supplied by an outside source, such as a battery. If the flux is established using permanent magnets, then this type of dc generator is called Permanent magnet dc generator.

If the flux is obtained by exciting field coils from some external source, that type of dc generator is called Separately excited dc generator. If field coils are excited by the generator itself to establish the required flux, then such type of dc generators are called Self-excited dc generators.

Generators are generally classified according to these methods of field excitation. On this basis, different types of dc generator are divided into the following three classes: Permanent magnet dc generators, Separately excited dc generators, Self-excited dc generators. Series Wound dc generator, Shunt Wound dc generator, Compound Wound dc generator. Types of dc generator. In permanent magnet dc machines, a permanent magnet is used to establish flux in the magnetic circuit. These generators are not found in industrial applications because of the low power generated from it. Such generators are employed only in small sizes like dynamos in motorcycles.

The behavior of a dc generator on load depends upon the method of field excitation adopted. Separately Excited D.C. Generators: A dc generator whose field magnet winding is supplied from an independent external d.c. source (e.g., a battery etc.) is called a separately excited generator. Separately excited dc generator. The figure shows the connections of a separately excited generator. The voltage output depends upon the speed of rotation of armature and the field current ( $E_g = \frac{fZNP}{60} A$ ). The greater the speed and field current, the greater is the generated EMF of DC Generator.

It may be noted that separately excited DC generators are rarely used in practice. The DC generators are normally of self-excited type. Also, read characteristics of separately excited dc generator. Armature current,  $I_a$  =  $I_L$  Terminal voltage,  $V = E_g - I_a R_a$  Electric power developed =  $E_g I_a$  Power delivered to load =  $E_g I_a - I R = I E - I R = V I_a$  Self-Excited D.C. Generators: A d.c. generator whose field magnet winding is supplied current

# Short shunt compound dc generator

from the output of the generator itself is called a self-excited generator.

A generator that supplies its own field excitation is called a self-excited generator. Self-excitation is possible only if the field pole pieces have retained a slight amount of permanent magnetism, called residual magnetism. When the generator starts rotating, the weak residual magnetism causes a small voltage to be generated in the armature. This small voltage applied to the field coils causes a small field current. Although small, this field current strengthens the magnetic field and allows the armature to generate a higher voltage. The higher voltage increases the field strength, and so on. This process continues until the output voltage reaches the rated output of the generator.

There are three types of self-excited dc generator depending upon the manner in which the field winding is connected to the armature, namely; Series generator Shunt generator Compound generator

1. DC Series Generator In a series-wound generator, the field winding is connected in series with armature winding so that whole armature current flows through the field winding as well as the load. The figure shows the connections of a series-wound generator. Since the field winding carries the whole of load current, it has a few turns of thick wire having low resistance.

A series-wound DC generator characteristic shows that the output voltage varies with load current. This is undesirable in most applications. For this reason, this type of generator is rarely used in everyday practice.

2. DC Shunt Generator In a shunt generator, the field winding is connected in parallel with the armature winding so that the terminal voltage of the generator is applied across it. The shunt field winding has many turns of fine wire having high resistance. Therefore, only a part of armature current flows through shunt field winding and the rest flows through the load. Also, read the characteristics of a shunt generator.

A combination of the two types can overcome the disadvantages of both. This combination of windings is called the compound wound DC generator.

3. DC Compound Generator In a compound-wound generator, there are two sets of field windings on each pole - one is in series and the other in parallel with the armature. In the compound-wound generator when load current increases, the armature voltage decreases just as in the shunt-wound generator. This causes the voltage applied to the shunt-field winding to decrease, which results in a decrease in the magnetic field.

Contact us for free full report

Web: <https://www.kary.com.pl/contact-us/>

Email: [energystorage2000@gmail.com](mailto:energystorage2000@gmail.com)

WhatsApp: 8613816583346

